



96200 / 96201 / 96210 / 96211 / 96220 / 96221 / 9617

The company named below has been authorized by Canadian Standards Association to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark -  - to these products according to the terms and conditions of the CSA Service Agreement.

022355X0000 September 1, 1993(Replaces:August 31, 1992)

CLASS 3231 02 (Re-examination Service)

Page 4

- Pressure switches, open type, Models 96200, 96201, 96210, 96211, 96220 and 96221 series, rated, with suffixes BB and GH, 240V ac, 5A; with suffix CC, 240V ac, 10A; with suffixes -T1, -T2, -T3.

Note: Open type (stripped) pressure and vacuum switches are Certified as components for use in other Certified equipment where the suitability of the combination is determined by the Canadian Standards Association.

- Pressure switches, open type, Models 96200, 96201, 96210, 96211, 96220 and 96221 series, rated, with suffixes BB and GH, 240V ac, 5A; with suffix CC, 240V ac, 10A; with suffixes -T4, -T5. CSA Enclosure 4.

- Pressure switches, enclosed, Model 9617, rated 15A, 480V ac max. CSA Enclosure Type 4.

Note: Certification for CSA Enclosure 4 applications is conditional upon the leads being enclosed in a conduit.

* * * * * * * * * *mwb