



E1H / D1T / D1H / D2T
SPRINKLER SYSTEMS
1 OF 3

IMO INDUSTRIES INC
BARKSDALE CONTROLS DIV
MR D MCAFEE
3211 FRUITLAND AVE
PO BOX 58843
LOS ANGELES CA 90058

Your most recent listing is shown below. Please review this information and report any inaccuracies to the UL Engineering staff member who handled your Assignment.

VOXZ April 20, 1993
Switches, Pressure

IMO INDUSTRIES INC BARKSDALE CONTROLS DIV , S1215 (N)
LOS ANGELES CA 90058 (A card)

Pressure-operated switches: Sprinkler system alarm and supervisory service, Cat. Nos. E1H-B15, -B15-P8-U, -B15-P8-PLS-U, -M15-U, -M15-P8-U, -M15-P8-PLS-U, rated 0.5 to 15 psi; E1H-B20-U, -B20-P8-U, -B20-P8-PLS-U, -M20-U, -M20-P8-U, -M20-P8-PLS-U, rated 1.0 to 20 psi; E1H-B90-Q18, -B90-U, -B90-P8-U, -B90-P8-PLS-U, -M90-U, -M90-P8-U, -M90-P8-PLS-U, rated 3.0 to 90 psi; E1H-B250-U, -B250-P8-U, -B250-P8-PLS-U, -M250-U, -M250-P8-U, -M250-P8-PLS-U, rated 10.0 to 250 psi may or may not be followed by suffixes -BR and/or -Q1 thru -Q99.
Pressure switches, Cat. Nos. D1H, D1T, D2T followed by A, B, C, E, F or H, followed by 2, 3, 1B, 80 or 150, may be followed by SS, followed by -UL (i.e. D1H-A3SS-UL).
Diaphragm and Rating:

Suffix	Adjustable Range PSI
2	0.015 to 1.7
2SS	0.015 to 1.7
3	0.03 to 3.0
3SS	0.03 to 3.0
80	0.50 to 80.0
80SS	0.50 to 80.0

Replaces S1215A dated March 20, 1990.
929536001 H6650 Underwriters Laboratories Inc.*

(Cont. on B card)
B11/0064444
498

For information on placing an order for UL Listing Cards in a 3 x 5 inch card format, please refer to the enclosed ordering information.

UNDERWRITERS LABORATORIES INC.

An independent, not-for-profit organization testing for public safety

333 Pfingsten Road
Northbrook, Illinois 60062-2096, USA
708/272-8800
Telex: 6502543343
FAX No. (708) 272-8129

1265 W&H Whitman Road
Melville, L.I., New York 11747-3081, USA
516/271-8200
Telex: 6852015
FAX No. (516) 271-8259

1655 Scott Blvd.
Santa Clara, California 95050-4169, USA
408/985-2400
Telex: 184219
FAX No. (408) 298-3256

12 Laboratory Drive
P.O. Box 13995
Research Triangle Park,
North Carolina 27709-3995, USA
919/549-1400
Telex: 4837928
FAX No. (919) 549-1842

RECEIVED
MAY - 7 1993
ENGINEERING



E1H / D1T / D1H / D2T
SPRINKLER SYSTEMS
2 OF 3

333 Pfingsten Road
Northbrook, Illinois 60062-2096
(708) 272-8800
FAX No. (708) 272-8129
MCI Mail No. 254-3343
Cable ULINC NORTHBROOK
Telex No. 6502543343

IMO INDUSTRIES INC
BARKSDALE CONTROLS DIV
Mr. D. McAfee
3211 FRUITLAND AVE
P O BOX 58843
LOS ANGELES CA 90058

Your most recent listing is shown below. Please review this information and report any inaccuracies to the UL Engineering staff member who handled your Assignment.

VOXZ
Switches, Pressure

March 20, 1990

IMO INDUSTRIES INC BARKSDALE CONTROLS
DIV

S1215 (N)
(B-cont. from A card)

150	1.50 to 150.0
150SS	1.50 to 150.0
18	0.40 to 18.0
18SS	0.40 to 18.0

Electrical ratings: Catalogs employing suffix B, 6.5 amps, 12-14 v, dc; 1.5 amps, 24-28 v, dc; 0.33 amp, 125 v, dc; 0.25 amp, 250 v, dc; 10 amps, 125-250 v, ac; 1/8 hp, 125 v, ac; 1/4 hp, 250 v, ac. Pilot duty 125 va, 125-250 v, ac. Catalogs employing suffix M, rated 3.3 amps, 12-14 v, dc; 1.0 amp, 24-28 v, dc; 0.25 amp, 125 v, dc; 0.10 amps, 250 v, dc; 10 amps, 125-250 v, ac; 1/8 hp, 125 v, ac; 1/4 hp, 250 v, ac. Pilot duty 125 va, 125-250 v, ac; Cat. Nos. D1H, D2H and D1T, 10 amp, 125-300 v, ac; 1/2 amp, 125 v, dc; 1/4 amp, 250 v, dc.
Pressure-operated switches: Sprinkler system alarm and supervisory service, Cat. Nos. E1H-G15-RD-U, -G15-P6-RD-U, -G15-P6-PLS-RD-U, rated 0.5 to 18 psi. E1H-G20-RD-U, -G20-P6-RD-U, -G20-P6-PLS-RD-U, rated 1.0 to 20 psi. E1H-G90-RD-U, -G90-Q2B, -G90-P6-RD-U, -G90-P6-PLS-RD-U, rated 3.0 to 90 psi. E1H-G250-RD-U, -G250-P6-RD-U, -G250-P6-PLS-RD-U, rated 10.0 to 250 psi. Electrical ratings: 15 amp at 125-250 v, ac; 8.5 amp

Replaces S1215B dated October 3, 1988, filed IMO DeLaval Inc., Barksdale Controls Div.

(Cont. on C card)

839536001 N6650 Underwriters Laboratories Inc.* 811/0064445

71

For information on placing an order for UL Listing Cards in a 3 x 5 inch card format, please refer to the enclosed ordering information.

UNDERWRITERS LABORATORIES INC.

RECEIVED IN

APR - 3 1990

ENGINEERING

An independent
not-for-profit organization
testing for public safety



Underwriters Laboratories Inc.

**E1H / D1T / D1H / D2T
SPRINKLER SYSTEMS
3 OF 3**

333 Pfingsten Road
Northbrook, Illinois 60062-2056
(708) 272-8800
FAX No. (708) 272-8129
MCI Mail No. 254-3343
Cable ULINC NORTHBRO
Telex No. 6502543343

**IMO INDUSTRIES INC
BARKSDALE CONTROLS DIV
Mr. D. McAfee
3211 FRUITLAND AVE
P O BOX 58843
LOS ANGELES CA 90058**

Your most recent listing is shown below. Please review this information and report any inaccuracies to the UL Engineering staff member who handled your Assignment.

**VOXZ
Switches, Pressure**

March 20, 1990

**IMO INDUSTRIES INC BARKSDALE CONTROLS
DIV**

**S1215 (N)
(C-cont. from B card)**

at 12 v. dc; 1.5 amp at 24 v. dc; 0.33 amp at 125 v. dc.

3211 FRUITLAND AVE P O BOX 58843

LOOK FOR LISTING MARK ON PRODUCT

Replaces S1215C dated July 9, 1987, filed IMO Deval Inc., Barksdale Controls Div.

939536001

Underwriters Laboratories Inc.®

811/0064446

72

For information on placing an order for UL Listing Cards in a 3 x 5 inch card format, please refer to the enclosed ordering information.

UNDERWRITERS LABORATORIES INC.

**RECEIVED IN
APR - 3 1990
ENGINEERING**

An independent,
not-for-profit organization
testing for public safety.